

# Wyalusing Municipal Authority

## March 2026 Water and Wastewater Report

### WWTP

- Influent Flow 1,973,100 (63,648 daily average)
- Effluent Flow: 1,814,000 (58,516 daily average)
- 6,000 gallons of sludge hauled to Wyoming Valley
- School lift station and force main easements.
- I have the sewer manholes measured and marked out on Homet Heights road. I will be getting with the township and setting up a date to start digging these up to get measurements for the risers and extensions needed to get them accessible.

### WTP

- 1,691,808 (54,574) gallons pumped from the Ballpark well.
- 18,270 pumped from Welles well.
- I met with Doug Brown concerning the easement of the old Welles water system reservoir. Turns out that he had copies of the original easement and forwarded it to me. We have a 50-foot-wide easement off Bowling Alley Road. When I finished digging up and disconnecting the water service to 74 Bowling Alley Road, I took the mini up and cleaned the road of all debris and downed trees. The road was washed out in spots due to poor drainage, so I fixed the areas that had washed out and created better diversions. Doug is willing to work with us at the bottom if we need more room to make the turn to come up the hill, for any future projects involving the property.
- It was discovered that the house at 140 Bowling Alley Road was still connected to the Welles water system, albeit it was not serving the primary residence. The line was valved off in the garage and was feeding two-yard hydrants on the property. The current owner, Jim Wilson, was not aware of this as he did not build the house. It was not known to be there and was hit By Isaac Milliard when he was doing some excavation work for the homeowner. It has since been disconnected, and the service line has been capped.
- We dug up the service line to 61 Taylor Ave, which is fed off Gaylord st. They have not had very good water pressure for years and it finally got to the point where there was hardly any pressure at all. There was a blockage between the main and the curb stop.
- PA Small Water and Sewer Systems Grant- well ownership and easement issues
- Spring flushing has begun.
- The borough is using the Mini this week down at the dump area to do some cleanup, including tearing down some old shed and chicken coops on the property.